CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3
Certificate No.: TC-5548

Format No: CP/TF/01

TEST RESULTS OF STEEL

Date: 12-02-20

Lab ID	:	CP-2020-05-11-15
Customer	:	Assistant Executive Engineer, Shettyhalli sub Division, BBMP, Bangalore.
Address	:	Shettyhalli Sub Division, BBMP, Bangalore.
Project Name	:	Construction of Concrete Retaining Wall and other Civil Works to Mallasandra Colony School in Ward No 13 Shettyhally Sub Division
Agency	:	M/S Technical Manager(West), Karnataka Rural Infrastructture Development Limitd, #280, 59th Cross Road , 17th C Main Road , 3rd Y Block , Rajajinagar, Bangalore-560010
Customer's Reference	:	EE/DD/W.O/533/2019-20
Source of Sample	:	Sample supplied by Agency
Sample Condition	:	Satisfactory
Date of Receipt	:	11-02-20
Sample Type	:	Sunvik
Reference to BIS codes	:	IS 1786-2008, IS:1608-2005(RA 2011), IS 1599-2012.
Date of test:	:	11-02-20

Sl.No	Identification of sample	Grade of the sample	Diameter of the steel bar	Weight of the sample	Yield stress	Tensile strength	Elongation	Bend test	Rebend test
			(mm)	(kg/m)	(N/mm2)	(N/mm2)	(%)		
4	Sunvik	Fe500	16	1.58	520	652	20.0%	Satisfactory	Satisfactory
5	Sunvik	Fe500	20	2.47	533	672	20.0%	Satisfactory	Satisfactory

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

FOR CIVIL Pro.

CIVIL Pro BANGALORE Sig Date

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

End of Report